


IECC Compliance Guide for Homes in Texas

Code: 2015 International Energy Conservation Code

Step-by-Step Instructions

- Using the climate zone map to the right, match the jurisdiction to the appropriate IECC climate zone. Use the simplified table of IECC building envelope requirements (below) to determine the basic prescriptive requirements for the thermal envelope associated with the jurisdiction.
- Use the “Outline of 2015 IECC Requirements” printed on the back of this sheet as a reference or a categorized index to the IECC requirements. Construct the building according to the requirements of the IECC and other applicable code requirements.



The 2015 International Energy Conservation Code

The 2015 IECC was developed by the International Code Council (ICC) and is currently available to states for adoption. The IECC is the national model standard for energy-efficient residential construction recognized by federal law. Users of this guide are strongly recommended to obtain a copy of the IECC and refer to it for any questions and further details on compliance. To obtain a copy of the 2015 IECC, contact the ICC or visit www.iccsafe.org. IECC compliance training is also available from many sources.

Limitations

This guide is an energy code compliance aid for Texas based upon the simple prescriptive option of the 2015 IECC. It does not provide a guarantee for meeting the IECC. This guide is not designed to reflect the actual energy code, with amendments, if any, adopted in Texas and does not, therefore, provide a guarantee for meeting the state energy code. For details on the energy code adopted by Texas, including how it may differ from the IECC, please contact your local building code official. Additional copies of this guide are available on www.reca-codes.com.

CLIMATE ZONE 4					
Armstrong	Cochran	Gray	Hutchinson	Oldham	Sherman
Bailey	Dallam	Hale	Lamb	Parmer	Swisher
Briscoe	Deaf Smith	Hansford	Lipscomb	Potter	Yoakum
Carson	Donley	Hartley	Moore	Randall	
Castro	Floyd	Hockley	Ochiltree	Roberts	
CLIMATE ZONE 3					
Andrews	Crockett	Hall	Knox	Parker	Tarrant
Archer	Crosby	Hamilton	Lamar	Pecos	Taylor
Baylor	Culberson	Hardeman	Lampasas	Presidio	Terrell
Blanco	Dallas	Harrison	Llano	Rains	Terry
Borden	Dawson	Haskell	Loving	Reagan	Throckmorton
Bowie	Delta	Hemphill	Lubbock	Red River	Titus
Brewster	Denton	Henderson	Lynn	Reeves	Tom Green
Brown	Dickens	Hood	Marion	Rockwall	Upshur
Burnet	Eastland	Hopkins	Martin	Runnels	Upton
Callahan	Ector	Howard	Mason	Rusk	Van Zandt
Camp	El Paso	Hudspeth	McCulloch	Sabine	Ward
Cass	Ellis	Hunt	Menard	San Augustine	Wheeler
Childress	Erath	Irion	Midland	San Saba	Wichita
Clay	Fannin	Jack	Mills	Schleicher	Wilbarger
Coke	Fisher	Jeff Davis	Mitchell	Scurry	Winkler
Coleman	Foard	Johnson	Montague	Shackelford	Wise
Collin	Franklin	Jones	Morris	Shelby	Wood
Collingsworth	Gaines	Kaufman	Motley	Smith	Young
Comanche	Garza	Kendall	Nacogdoches	Somervell	
Concho	Gillespie	Kent	Navarro	Stephens	
Cooke	Glasscock	Kerr	Nolan	Sterling	
Cottle	Grayson	Kimble	Palo Pinto	Stonewall	
Crane	Gregg	King	Panola	Sutton	
CLIMATE ZONE 2					
Anderson	Calhoun	Galveston	Karnes	Medina	Uvalde
Angelina	Cameron	Goliad	Kenedy	Milam	Val Verde
Aransas	Chambers	Gonzales	Kinney	Montgomery	Victoria
Atascosa	Cherokee	Grimes	Kleberg	Newton	Walker
Austin	Colorado	Guadalupe	La Salle	Nueces	Waller
Bandera	Comal	Hardin	Lavaca	Orange	Washington
Bastrop	Coryell	Harris	Lee	Polk	Webb
Bee	DeWitt	Hays	Leon	Real	Wharton
Bell	Dimmit	Hidalgo	Liberty	Refugio	Willacy
Bexar	Duval	Hill	Limestone	Robertson	Williamson
Bosque	Edwards	Houston	Live Oak	San Jacinto	Wilson
Brazoria	Falls	Jackson	Madison	San Patricio	Zapata
Brazos	Fayette	Jasper	Matagorda	Starr	Zavala
Brooks	Fort Bend	Jefferson	Maverick	Travis	
Burleson	Freestone	Jim Hogg	McLennan	Trinity	
Caldwell	Frio	Jim Wells	McMullen	Tyler	

	Windows			Insulation				Foundation		
	Fenestration U-Factor	Skylight U-Factor	Glazed Fenestration SHGC	Ceiling R-Value	Wood Frame Wall R-Value	Mass Wall R-Value	Floor R-Value	Basement Wall R-Value	Slab R-Value and Depth	Crawl Space Wall R-Value
Zone 4	0.35	0.55	0.40	49	20 or 13 + 5	8/13	19	10/13	10, 2 ft	10/13
Zone 3	0.35	0.55	0.25	38	20 or 13 + 5	8/13	19	5/13	0	5/13
Zone 2	0.40	0.65	0.25	38	13	4/6	13	0	0	0

Outline of 2015 IECC Requirements for Texas Homes

The simplified table of building envelope requirements (on the previous page) applies to new residential buildings, as defined in the IECC, with wood framing and/or mass walls. For steel-framed buildings, the same window requirements apply; however, refer to IECC section R402.2.6 for specific insulation R-value requirements. The table also applies to all additions, alterations and replacement windows. The table is based upon the thermal envelope requirements in the 2015 IECC's prescriptive compliance option for the appropriate climate zones (Table R402.1.2) and does not reflect any state-specific amendments to the IECC.

Fenestration (IECC Sections R303.1.3, R402.3, R402.5)

- Fenestration (including all windows and doors) and Skylight U-factors are maximum acceptable levels. The Glazed Fenestration SHGC maximums apply to all windows, skylights and glazed doors. An area-weighted average of fenestration products is permitted to satisfy these requirements. (See IECC section R402.3.)
- Window, door and skylight U-factors and SHGCs must be determined by an accredited, independent laboratory, and labeled and certified by the manufacturer, in accordance with a National Fenestration Rating Council (NFRC) rating. Products without an NFRC label must use the default values in IECC section R303.1.3. See www.nfrc.org for more details on the NFRC rating system.
- Windows, skylights, and sliding glass doors must also be labeled in a manner to show that they meet the IECC's air infiltration requirements.
- Up to 15 square feet of glazed fenestration is permitted to be exempt from the U-factor and SHGC requirements. One side-hinged opaque door assembly up to 24 square feet is exempted from the Fenestration U-factor requirement. Special exceptions may apply for Fenestration U-factor requirements in thermally isolated sunrooms. (See IECC section R402.3.5.)

Insulation (IECC Sections R303.1.4 and R402.2)

- Insulation R-values are minimum acceptable levels and must be determined according to Federal Trade Commission rule.
- R-values for walls represent the sum of cavity insulation plus insulated sheathing, if any. The second R-value for mass walls applies when more than half the insulation is on the interior of the mass wall.
- The insulation for basement walls must be from the top of the wall down 10 feet below grade or to the basement floor, whichever is less. Basement wall insulation is not required in warm-humid locations as defined in IECC Figure R301.1 and Table R301.1. Insulation requirements for crawl space walls are further specified in IECC section R402.2.11.
- Floor insulation must be installed to maintain contact with the underside of the subfloor decking. Refer to the code for details allowing insulation to be installed on the lower side of the ceiling cavity.
- Access doors from conditioned spaces to unconditioned spaces (e.g., attics and crawl spaces) shall be weatherstripped and insulated to a level equivalent to the insulation on the surrounding surfaces. Vertical access doors are permitted to meet the fenestration requirements in Table R402.1.2.
- Insulation requirements for slab on grade floors are further specified in IECC section R402.2.10. R-5 shall be added to the required slab edge R-values for heated slabs.

- Special Insulation exceptions related to ceilings with or without attic spaces, masonry veneer and thermally isolated sunrooms are set forth in IECC section R402.

Ducts (IECC Section R403.3)

- Ducts must be tested and verified to have total leakage of no more than 4cfm/100 sq. ft. (or 3cfm if air handler is not installed), except where air handler and all ducts are located inside conditioned space. Air handlers and filter boxes must also be properly sealed.
- Supply and return ducts shall be sealed and insulated as follows:

Duct Location	< 3 inches in diameter	≥ 3 inches in diameter
Attic	R-6	R-8
Other portions of the building	R-4.2	R-6
Completely inside conditioned space	Exempt	Exempt

Air Sealing (IECC Section R402.4)

- The building envelope is required to be properly sealed and tested, and verified as having an air leakage rate no higher than 3 ACH at 0.2 inch w.g. (50 Pascals) in climate zones 3 and 4, and no higher than 5 ACH at 0.2 w.g. (50 Pascals) in climate zone 2.

Documentation (IECC Sections R103, R303.3, R401.3)

- The appropriate construction documents and preventative maintenance information must be provided, along with a permanent certificate listing certain insulation, window and HVAC performance information.

Systems (IECC Section R403)

- HVAC system must be properly sized in accordance with ACCA Manual S based on building loads calculated in accordance with ACCA Manual J or other approved methodologies. New or replacement heating and cooling equipment must meet or exceed federal minimum efficiency requirements for geographic location in which it is installed.
- Temperature controls must be installed, including a programmable thermostat where required.
- Mechanical system piping must be insulated to a minimum of R-3. Hot water piping must be insulated to R-3, with certain exceptions.
- Specific requirements apply to circulating hot water systems, mechanical ventilation, snow melt systems, and pools.

Lighting (IECC Sections R202 and R404.1)

- A minimum of 75% of lamps in permanently installed fixtures must be high-efficacy as defined in the IECC.